



OFFICE OF THE DEPUTY FIRE OFFICER
ROURKELA CIRCLE, ROURKELA

(dforkl-ofs@gov.in)

No.83/RKL CIRCLE

Dt.15.02.2025

To

The Manager,
Radha Soami English School, AT -Sector-C, Bondamunda PS-Bisra
Dist.-Sundargarh

Ref: - Application No.FSC1307210062025000001

Sub: - Issuance of Fire Safety Certificate in respect of Radha Soami
English School,AT- Sector-C,Bondamunda,Dist.-Sundargarh

Sir,

With reference to the subject cited above, it is to intimate that a team of Odisha F & ES visited the aforesaid buildings of Radha Soami English School, At-Sector-C, Bondamunda, Dist.-Sundargarh on 14.02.2025. It is ascertained that the buildings are Ground floor building and having a built up area less than One thousand square meters and is not likely to have risk of fire. So, it is not coming under Odisha Fire Prevention and Fire Safety Rule, 2017 read with Odisha Fire Prevention and Fire Safety Rule (Amendment), 2019 as per rule -9 (j).

In this regards, Fire Safety Certificate is not required for the aforesaid buildings as per above provisions.

However, 06nos. of Fire Extinguishers have been installed in the aforesaid building to meet any exigencies and were checked and tested thoroughly and found in excellent working order.

This is for favour of your kind information and necessary action please.

Yours faithfully,

6-12
15/2/25

(Umakanta Naik)

Deputy Fire Officer

Rourkela Circle, Rourkela

Deputy Fire Officer
Rourkela Circle, Rourkela